

LOCKOUT/TAGOUT PROCEDURE

College of Saint Benedict

Date of Last Revision: October 8, 2004

TASK – Repair or Maintenance on Cooling Tower

Equipment to disable:

- Fans

Supplies needed:

- Padlocks
- Tags

Procedure

This procedure is to be used in conjunction with the General Lockout Procedure.

Step 1:

Disable power by throwing fan disconnects located on each side of cooling tower. Make sure two disconnects are disabled. Secure with padlock. Apply tag.



Procedure Approval

Signature: _____

Department: _____ Date: _____